




# Best Practices in Planning New Transmission System

Central Transmission Utility of India Ltd.

BIMSTEC, 13.05.2026

# Focus Areas – 5 E's



Energy



Environment



Efficiency



Economics




Empower

Central Transmission Utility (CTU) came into existence through “The Electricity Regulatory Commission Act, 1998”. POWERGRID was designated as CTU by GoI on December 31, 1998 for five years.

In line with provisions of the Electricity Act, 2003, POWERGRID, a CPSE, engaged in execution and maintenance of transmission system was notified by the MoP as the CTU vide Gazette notification dated 27.11.2003.



CTUIL was incorporated as a wholly owned subsidiary of POWERGRID on 28.12.2020. CTUIL started discharging CTU functions w.e.f 01.04.2021.

## Key Functions of CTUIL





# Power System Overview


# Indian Grid: Installed Capacity




All India Peak Demand (till date):  
**256GW** (in Apr'26)



# Indian Grid: Growth




Growth in Transmission line (220kV & above)  
CAGR: ~4%



Growth in Transformation Capacity (220kV & above)  
CAGR: ~8%


# Indian Grid: RE Growth




**CAGR:**  
**Wind: 9%**  
**Solar: 45%**

Source: As per CEA report

# Indian Grid: Growth





*The National Grid facilitates seamless transfer of power from surplus region to deficit regions and has enabled a strong and vibrant power market along with integration of large scale Renewable Power generation capacity to Indian Grid.*




# Per Capita Consumption & Demand: Growth

- Per-capita electricity Consumption is computed as the ratio of estimated electricity consumption to estimated mid-year population*




# Distribution of Energy Resources



## Solar Radiation Atlas




## RE Potential Planned to be Integrated by 2030



## Wind Atlas



Total RE Planned for Integration = 518 GW



Off Shore Wind Potential : 60 GW, Each at Gujarat & Tamil Nadu off Coast


Offshore Wind

# Transmission Planning Process

## ❖ **Guideline document for Transmission Planning purpose for Indian Grid**

The manual on transmission planning criteria published by CEA covers the planning philosophy, the information required from various entities, permissible limits, reliability criteria, broad scope of system studies, modelling and analysis and gives guidelines for transmission planning.

# Transmission System Planning Process



# Planning of Transmission System

## Inputs

### Demand


- Peak Demand as per EPS/Projected demand by States.
- GNA applications for Bulk consumer
- Demand of Green Hydrogen/Ammonia by MNRE
- Demand for Data Centers by MEITY
- Storage Demand during the day.
- Daily Load Curve for Summer, Monsoon, Winter
- Diversity of Demand across the region

### Generation


- Fuel-wise Installed Capacity.
- Dispatch Factor for '9' scenarios over '3' seasons.
- Dispatch priorities:
  - Thermal On-bar IC to meet Evening peak demand.
  - Must Run Dispatches.
  - Storage Dispatch.
  - Other Generation.
- During Solar Max scenario, the On-bar Thermal IC is dispatched @ Tech. min. of 40%.

# Power System Planning


## Connectivity Regulations 2009




## GNA Regulations 2022




# Power System Planning



Point to Point Transfer



Point to Region Transfer



Point to All India Transfer

# Integration of Renewable Energy New Technologies

# Challenges : RE Integration

## Short Gestation period

- Planning & development of evacuation system based on potential renewable energy zones (Green Energy Corridors)

## Intermittent

- Enlarging Balancing Area through transmission expansion
- Ancillary Support Services
- Forecasting of Renewable output

## Variable Output


- Balancing resources
- Dynamic reactive power compensators
- Energy Storage System

## Inertial Support

- Synthetic Inertia from Inverter/WTG
- Energy Storage System
- Synchronous Condenser

**Compliance to Technical Standards; Standard Operating Procedure**

# Effect of Increased RE Penetration on Load Curve




Source: NLDC SCADA data, CAGR assumed: 8%

Morning Peak @ 140 MW/min for 40 minutes  
Evening Peak @ 200 MW/min for 40 minutes

## Flexibility:

- High Ramp Rate Requirement
- Low Thermal Generation firing high RE Period
- Energy Storage
- Bidirectional Flow of Power
- Maintaining Grid Parameters, Stability and Grid Security

# Typical Load Curve




Source: Grid India

# Typical Load Curve

**GW**

## All India Peak Day Demand

7th Jul-2021



# Scenarios Considered

## Seasons Considered



Monsoon



Summer



Winter

## Diurnal & Nocturnal Cases



Solar Max (around 12 PM)



Evening Peak (b/w 6 to 11 PM)




Night Off Peak (b/w 12 to 6 AM)

- Monsoon (Aug'27)
  - Solar max (Sc-1)
  - Evening peak (Sc-2)
  - Night off peak (Sc-3)

- Summer (Jun'27)
  - Solar max (Sc-4)
  - Evening peak (Sc-5)
  - Night off peak (Sc-6)

- Winter (Feb'28)
  - Solar max (Sc-7)
  - Evening peak (Sc-8)
  - Night off peak (Sc-9)

# Load Generation Balance for FY 2030-31



*All figures are in GW*

# Non-Fossil 2030 Generation

GW as of->	Mar 2014	Mar 2026	Mar 2030
Solar	3	118.7*	240*
Wind	21	56	100
<b>VRE total</b>	<b>24</b>	<b>174.7</b>	<b>340</b>
Rooftop & Off Grid Solar	-	31.5#	60#
Hydro incl. Small	44	56.6^	70^
Nuclear	5	8.7	15
Biomass & others	8	12	15
<b>Total</b>	<b>81</b>	<b>283.5</b>	<b>500</b>

\*3.9 GW Hybrid solar








# 5.8 GW Off Grid Solar

^5 GW Small Hydro

# Power Supply Position in FY 2030-31

- Surplus of about **48-95 GW** across the seasons and dispatch scenarios requiring RE Curtailment even if there is no Transmission Constraint.
- The extent of Surplus/Curtailment shall further increase to
  - ❖ 72-119 GW - if 24 GW of Green Hydrogen considered in the demand is delayed.
  - ❖ 112-160 GW - if 64 GW of storage comprising 38 GW of PSP and 26 GW of BESS is delayed.
  - ❖ 68-115 GW - if Technical Minimum of Thermal On-Bar IC is considered as 55% instead of 40%
  - ❖ 102 - 149 GW - if 50% of each of the above three is not achieved.
- **Looking into such a huge surplus :**
  - **Additional RE should be allowed injection during non-solar hours only for improvement in utilization of ISTS network.**

# Power Quality



- Power Factor
- Harmonics
- Unbalance
- Interruptions
- Voltage Sag
- Voltage Swell
- Transients
- Flicker

# National Green Hydrogen Mission

## EXPECTED OUTCOMES OF THE MISSION BY 2030

India's Green Hydrogen Production Capacity will Reach at Least  
**5 MMT Per Annum**



Renewable Energy Capacity Addition of  
**~125 GW**



Over  
**₹8 lakh crore**  
in Total Investments





Create Over  
**6 lakh**  
Full Time Jobs



**50 MMT**  
per annum  
of CO2 Emissions  
are Expected to be Averted




# Energy Storage Applications




Energy storage mediates between variable sources and variable loads.

Power- Energy Continuum of energy storage Technologies and applications



# Transmission Infrastructure: RE Integration

## HVDC Links, STATCOM/SVC & REMC(s) in India



## System Stability

- 17 no. of Hybrid STATCOMs
- 4 no. of SVC (2500MVA<sub>r</sub>)
- 48 nos. FSC/TCSC

## Bulk Power Transfer

- 3 no of  $\pm 800$ kV HVDC Bipole (18GW)
- 5 no of  $\pm 500$ kV HVDC Bipole (10.5GW)
- 1 no of  $\pm 320$ kV VSC HVDC (2GW)
- 4 no of HVDC Back to Back (3 GW)

# Optimized ROW through New Tower & Conductor Designs


## Advantages of using higher voltage level

- Higher power carrying capacity and minimized losses.
- Saving forest area, tree/vegetation cover, loss of agricultural production.
- Saving quantity of steel and conductor material used.


	ROW (m)	Capacity (MW)	MW/m-RoW
400kV (D/c)	46	1000	22
765kV (S/c)	64	2100	33
765kV (D/c)	69	4200	61
±500kV HVDC	52	2500	48
±800kV HVDC	70	6000	90
1200 kV UHVAC	100	8000	80

HVAC vs. HVDC (for 10GW)


HVAC 400 kV



HVAC 765 kV



HVDC ±800 kV




# Transmission using HVAC vs HVDC

765kV D/C



Cost




$\pm 800$ kV HVDC



# Cross Border Interconnections under Consideration

OSOWOG



# New Technologies in Power Sector



Condition monitoring & Predictive maintenance using AI/ML algorithms



Process Bus Technology



**Dynamic Line Loading (DLL)**



**BESS as transmission infrastructure**



Synchronous Condenser



**Grid Forming Inverters**

THANK YOU...!!!